

The following information changes the RFT documents issued on Tuesday March 5, 2024.

GENERAL INFORMATION

Item 1: See 'Addendum M 01' dated March 19, 2024 issued by the Consultant (1 page)

End of Addendum 1

1 QUESTIONS AND RESPONSES

Q. Pot feeder and filter housing are piped in series. It is preferable to have them piped in parallel so that the pot feeder can be isolated when not in use. Also adding a flow indicator just before or after the filter is an easy way to tell if the filter is plugged or not.

R. The pot feeder, filter housing, and their associated piping are going to be reused as they currently exist, so their upgrade and modification are not within the scope of work.

END OF ADDENDUM M 01